



DEPARTMENT OF
REGULATORY AND ECONOMIC RESOURCES
MIAMI-DADE PERMITTING AND INSPECTION CENTER
11805 S.W. 26TH STREET (CORAL WAY)
MIAMI, FL 33175

NOTICE TO ALL PROFESSIONAL ENGINEERS A SELECTIVE COORDINATION FORM FOR PLANS REVIEW WILL BE REQUIRED

Effective **January 1, 2015**, a selective coordination form will be required for all projects which include **ELEVATORS, DUMBWAITERS, ESCALATORS, MOVING WALKWAYS, WHEELCHAIR LIFTS AND STAIRWAY CHAIRLIFTS, FIRE PUMPS, EMERGENCY SYSTEMS, LEGALLY REQUIRED STANDBY SYSTEMS, and CRITICAL OPERATIONS POWER SYSTEMS (COPS).**

This form provides documentation to assure compliance with the following National Electrical Code (NEC) NFPA 70 the current version recognized by the Florida Building Code Chapter 27 is the NEC 2008 edition and requirements for selective coordination are found directly in articles 240, 620, 695, 700, 701 and 708.

Should you have any questions, please contact Mr. Stuart Bazerman, Division Director, Electrical for the Department of Regulatory and Economic Resources, at (786) 315-2083, Mon.-Fri., 7:30 am – 4 pm, excluding legal holidays or via e-mail to bldgdept@miamidade.gov.

Thank you.